

試驗報告

報告編號：HB-20-04861

C-20-19807

頁數：1 OF 1

報告日期：109年07月29日

工程名稱：臺北市內湖區河濱高中基地公共住宅統包工程
 業主：臺北市政府都市發展局
 監造單位：亞新工程顧問股份有限公司
 承包商：中華工程股份有限公司
 委託單位：中華工程股份有限公司
 供料廠商：特欣國際股份有限公司
 样品名稱：抗霉抗汙細縫填縫劑(GR2101)
 構結部位：泥作工程
 取樣人員：亞新工程顧問股份有限公司(謝廣怡)、中華工程股份有限公司(陳俊毅)
 送驗人員：亞新工程顧問股份有限公司(謝廣怡)、中華工程股份有限公司(陳俊毅)
 會驗人員：亞新工程顧問股份有限公司(李世瑞)、中華工程股份有限公司(李家湘)
 收件日期：109年06月23日
 試驗日期：109年07月01日~109年07月29日
 會驗日期：109年07月29日
 註：1. 以上資料由顧客提供(收件及試驗日期除外)
 2. 除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製
 3. 下述報告內容標示#處由顧客提供

試驗結果：

試驗項目	試驗方法	試驗結果	#顧客要求值
抗壓強度(psi) 28天	參考 CNS 1010(1993)	7615	≥5000

註：#1. 配比(重量比)=抗霉抗汙細縫填縫劑(GR2101)：水=1000：380

2. 本試驗之樣品不在 TAF 認證範圍內，故無法出具 TAF 標誌之報告。

3. 本試驗報告之試驗地點於新北市五股區(新北產業園區)五權路55號。

報告簽署人

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWC 8229650